



NOTES:

1. LOWERED SECTION TO BE OF DUCTILE IRON CLASS 52 MECHANICAL JOINT PIPE OR PVC C-900 OR PVC C-905 PIPE WITH RESTRAINED JOINTS.
2. THE DESIGN ENGINEER SHALL CALCULATE LENGTH (L) OF RESTRAINED SECTION.
3. USE APPROPRIATE TYPE RESTRAINT FOR DUCTILE IRON OR PVC.

CITY OF NORFOLK – DEPARTMENT OF UTILITIES
STANDARD DETAILS

SCALE:
NOT TO SCALE

LOWERING WATER MAIN OR NEW CONSTRUCTION

DRAWING NO.
CW 06

DATE: 03/07